

Our reference: COM/2025/295

Decision notice – approval (with conditions)

(Given under section 63(2) of the *Planning Act 2016*)

Date of decision notice: 25 February 2026

Applicant details

Applicant name: Cip Constructions Group (Qld) Pty Ltd
Applicant contact details: C/- Gassman Development Perspectives
PO BOX 392
BEENLEIGH QLD 4207

Application details

Application number: COM/2025/295
Approval sought: Development Permit for Operational Works
Details of proposed development: Operational Works for Infrastructure and Vehicle Access Works

Location details

Street address: Lot 506 Coastlink Court, STAPYLTON QLD 4207
Real property description: PT1 Lot 506 SP329487

Decision

Date of decision: 23 February 2026
Decision details: Under Delegated Authority, the Principal Civil Engineer has resolved to approve the development application in full with conditions.

Referral agency(s) for the application

Not applicable – no part of the application required referral.

Details of the approval

Development approval: Operational Works for Infrastructure (water and footpath) and Vehicle Access Works (5 x vehicle crossings).

Conditions

The conditions that have been imposed by Council, as Assessment manager, are enclosed.

Properly made submissions

Not applicable—No part of the application required public notification.

Currency period for the approval (section 85 of the *Planning Act 2016*)

In accordance with section 85 of the *Planning Act 2016*, this approval has a currency period of two years.

Approved plans and drawings

Approved plans and drawings are attached and are identified in the conditions imposed by Council as the Assessment manager.

Appeal rights

Applicant	You have appeal rights in relation to this decision. An appeal may be made against, as applicable: • the refusal of part of the development application; or • a provision of the development approval; or • if a development permit was applied for, the decision to give a preliminary approval. An appeal must be started within 20 business days after this notice is given to you. An appeal may be made to the Planning and Environment Court or, for certain matters which are identified in section 1(2) of Schedule 1 of the <i>Planning Act 2016</i>, to a development tribunal. An appeal is started by lodging a notice of appeal with the registrar of the Planning and Environment Court or a development tribunal, as applicable. The notice of appeal must be in the approved form, succinctly state the grounds of the appeal and be accompanied by the required fee. An appellant to the Planning and Environment Court must give a copy of the notice of appeal, within 10 business days after the appeal is started, to the persons identified in section 230(3) of the <i>Planning Act 2016</i>. A person who is appealing to the Planning and Environment Court must comply with the rules of the court that apply to the appeal. An extract of Chapter 6, Part 1 and Schedule 1 of the <i>Planning Act 2016</i> is attached to this notice, which sets out further information about the appeal rights.
-----------	---

For further information please contact Daniel Marcano, Civil Engineer on 07 2114 3236, or via email mail@goldcoast.qld.gov.au who will be pleased to assist.

AUTHORISED BY



Nathan Seiler

Principal Civil Engineer

For the Chief Executive Officer

Council of the City of Gold Coast

Enc:

Conditions imposed by Council as Assessment manager

Attach:

Stamped approved plans and drawings

Appeal rights extracts

Conditions imposed by Council as Assessment manager

General																																								
1	Timing a All conditions of this development approval must be complied with at no cost to Council at all times, unless otherwise stated in another condition.																																							
2	Approved drawings Undertake and maintain the development generally in accordance with the following drawings including as amended in red by the Council: <table><tr><th colspan="5">Civil Engineering</th></tr><tr><th>Drawing Title</th><th>Author</th><th>Date</th><th>Drawing No.</th><th>Ver</th></tr><tr><td>Water Meter Plan and Details</td><td>Gassman Development Perspectives</td><td>12/02/26</td><td>6349 ENG WM 001</td><td>B</td></tr><tr><td>Vehicle Crossing Plan and Details Sheet 1 of 3</td><td>Gassman Development Perspectives</td><td>18/09/25</td><td>6349 ENG VXO 400</td><td>A</td></tr><tr><td>Vehicle Crossing Plan and Details Sheet 2 of 3</td><td>Gassman Development Perspectives</td><td>18/09/25</td><td>6349 ENG VXO 401</td><td>A</td></tr><tr><td>Vehicle Crossing Plan and Details Sheet 3 of 3</td><td>Gassman Development Perspectives</td><td>18/09/25</td><td>6349 ENG VXO 402</td><td>A</td></tr><tr><td>Footpath Connection Layout Plan</td><td>Gassman Development Perspectives</td><td>18/09/25</td><td>6349 ENG OPW 480</td><td>A</td></tr></table> And in relation to any approved Vehicle Crossing ensure that: - i The concrete is 175mm thick having a minimum of N32 grade. The minimum steel reinforcement is SL72 mesh with a minimum 50 mm top cover. - ii Stormwater kerb adaptors are clear from the crossing and entirely contained within the frontage of the subject site. - iii The vehicular crossing is located clear from all utility services. - iv Grades comply with <i>Institute of Public Works Engineering Australasia (IPWEA) standard drawing RSD-102</i>. - v Standard change in grade requirements in AS2890.1 is complied with. The conditions of this approval are to be read in conjunction with the attached stamped approved drawings. Where a conflict occurs between the conditions of this approval and the stamped approved drawings, the conditions of this approval shall take precedence.					Civil Engineering					Drawing Title	Author	Date	Drawing No.	Ver	Water Meter Plan and Details	Gassman Development Perspectives	12/02/26	6349 ENG WM 001	B	Vehicle Crossing Plan and Details Sheet 1 of 3	Gassman Development Perspectives	18/09/25	6349 ENG VXO 400	A	Vehicle Crossing Plan and Details Sheet 2 of 3	Gassman Development Perspectives	18/09/25	6349 ENG VXO 401	A	Vehicle Crossing Plan and Details Sheet 3 of 3	Gassman Development Perspectives	18/09/25	6349 ENG VXO 402	A	Footpath Connection Layout Plan	Gassman Development Perspectives	18/09/25	6349 ENG OPW 480	A
Civil Engineering																																								
Drawing Title	Author	Date	Drawing No.	Ver																																				
Water Meter Plan and Details	Gassman Development Perspectives	12/02/26	6349 ENG WM 001	B																																				
Vehicle Crossing Plan and Details Sheet 1 of 3	Gassman Development Perspectives	18/09/25	6349 ENG VXO 400	A																																				
Vehicle Crossing Plan and Details Sheet 2 of 3	Gassman Development Perspectives	18/09/25	6349 ENG VXO 401	A																																				
Vehicle Crossing Plan and Details Sheet 3 of 3	Gassman Development Perspectives	18/09/25	6349 ENG VXO 402	A																																				
Footpath Connection Layout Plan	Gassman Development Perspectives	18/09/25	6349 ENG OPW 480	A																																				
3	When the approval lapses if works is not completed This approval will lapse if the works is not completed within six years of works having substantially started, in accordance with section 88 of the Planning Act 2016.																																							
Engineering																																								
4	Rectification of Council's infrastructure a Rectify any damage caused to Council infrastructure (including kerb, channelling, service pits, footpaths and water and sewer reticulation networks) prior to an 'on maintenance' inspection, at no cost to Council. b Maintain the rectified Council infrastructure at no cost to Council until the asset is accepted "off maintenance" by the City in accordance with the procedures in City Plan Policy SC6.12 – Land development guidelines, Section 6 – Water supply and sewerage reticulation standards, Section 7 – Procedures, Section 8.5 – As-constructed requirements, Section 9 - Specifications and Section 10 – Standard drawings.																																							
5	Footpaths a Construct and maintain the footpath identified in the approved drawings condition at no cost to Council until the asset is accepted "off maintenance" by the City in accordance with the																																							

	procedures in City Plan Policy SC6.12 – Land development guidelines, section 2 – Transport network standards, Section 7 - Procedures, Section 8.5 - As-constructed requirements, Section 9 - Specifications and section 10 - Standard drawings. b Ensure that there is a minimum 300mm circumferential separation between any footpath and the outer edge of existing/new power poles. Fill the space with compacted cold-mix asphalt to a minimum depth of 50mm.																									
6	Construction of vehicular crossing Construct the vehicular crossing generally in accordance with the Driveways and vehicular crossing code of the City Plan and include in particular: i. Requirements of the Manual of Uniform Traffic Control Devices, Part 3 – Works on Roads.																									
Sewer and Water Works																										
7	Water connection Construct and maintain the water reticulation system identified in the approved drawings condition at no cost to Council until the asset is accepted “off maintenance” by the City in accordance with the procedures in City Planning Policy SC6.12 – Land development guidelines. i Conduits are required to be installed to service the proposed development by thrust boring the road (open cutting of the road is not permitted) to connect to Council's potable water supply network. ii The maintenance period for these works is twelve (12) months. The maintenance bond requirements to be followed as per the Land Development Guidelines. iii Remove redundant water meters/connections. <i>Notes:</i> i An “Application Work on the City’s infrastructure” form is required for item ii above. ii The development’s sewerage connection must be completed and approved by Council prior to <i>an application for a Pre-start meeting for the approved water connection.</i>																									
Construction Management																										
8	Certification of works Provide Council with certificates prepared by qualified expert(s) from the discipline(s) listed below, confirming as follows: <table><tr><th colspan="5">Civil Engineering</th></tr><tr><th>Certified document</th><th>Certification date</th><th>Plan/ Drawing</th><th>Expert discipline</th><th>Requesting Council Section</th></tr><tr><td>Appendix A Certification from the Land Development Guidelines</td><td>Upon practical completion of works.</td><td>-</td><td>Registered Professional Engineer Queensland (RPEQ)</td><td>Contributed Assets</td></tr></table> The certification is to confirm: • All works have been undertaken generally in accordance with the approval. <table><tr><th colspan="5">Contributed Assets</th></tr><tr><th>Certified document</th><th>Certification date</th><th>Plan/ Drawing</th><th>Expert discipline</th><th>Requesting Council Section</th></tr></table>	Civil Engineering					Certified document	Certification date	Plan/ Drawing	Expert discipline	Requesting Council Section	Appendix A Certification from the Land Development Guidelines	Upon practical completion of works.	-	Registered Professional Engineer Queensland (RPEQ)	Contributed Assets	Contributed Assets					Certified document	Certification date	Plan/ Drawing	Expert discipline	Requesting Council Section
Civil Engineering																										
Certified document	Certification date	Plan/ Drawing	Expert discipline	Requesting Council Section																						
Appendix A Certification from the Land Development Guidelines	Upon practical completion of works.	-	Registered Professional Engineer Queensland (RPEQ)	Contributed Assets																						
Contributed Assets																										
Certified document	Certification date	Plan/ Drawing	Expert discipline	Requesting Council Section																						

	<table><tr><td>Requirements of Council Water and Sewerage acceptance testing guideline</td><td>Prior to request to accept on maintenance or connect to existing mains</td><td>Approved Drawings</td><td>Registered Professional Engineer of Queensland (RPEQ)</td><td>Contributed Assets</td></tr></table> The certification is to confirm: - i Constructed works comply with necessary standards and confirm level and location details. - ii Installed components meet specifications and standards for materials and design and installation specifications and acceptance testing requirements.	Requirements of Council Water and Sewerage acceptance testing guideline	Prior to request to accept on maintenance or connect to existing mains	Approved Drawings	Registered Professional Engineer of Queensland (RPEQ)	Contributed Assets	
Requirements of Council Water and Sewerage acceptance testing guideline	Prior to request to accept on maintenance or connect to existing mains	Approved Drawings	Registered Professional Engineer of Queensland (RPEQ)	Contributed Assets			
9	Availability of approved plans, drawings and reports Retain a copy of this decision notice and stamped approved plans, drawings and reports on site at all times during construction. Any contractors undertaking approved work (including tree removal or relocations) must be directly provided with a copy of these conditions and instructed as to the need to comply with them.						
10	Supervision of works During construction of any works the following professionals must be appointed to supervise the below described actions: <table><tr><th colspan="2">All works approved by this permit</th></tr><tr><th>Expertise required of the suitably qualified professional</th><th>Actions to be overseen by the professional</th></tr><tr><td>Registered Professional Engineer of Queensland (RPEQ)</td><td>All supply, installation, construction, testing and commissioning of works</td></tr></table>	All works approved by this permit		Expertise required of the suitably qualified professional	Actions to be overseen by the professional	Registered Professional Engineer of Queensland (RPEQ)	All supply, installation, construction, testing and commissioning of works
All works approved by this permit							
Expertise required of the suitably qualified professional	Actions to be overseen by the professional						
Registered Professional Engineer of Queensland (RPEQ)	All supply, installation, construction, testing and commissioning of works						
11	Transport of soil / fill / excavated material During the transportation of soil and other fill / excavated material: - a All trucks hauling soil, or fill/excavated material must have their loads secure and covered. - b Any spillage that falls from the trucks or their wheels must be collected and removed from the site and streets along which the trucks travel on a daily basis. - c Prior to vehicles exiting the site, measures must be taken to remove the soil from the wheels of the vehicles to prevent soil and mud being deposited on public roads.						
12	For construction issue drawings – Water and Sewerage Prepare and provide for Council’s review and acceptance, drawings issued as “for construction” the Water and Sewerage design drawings amended following potholing undertaken as part of preliminary site works prior to requesting a prestart. Ensure that any design changes identified following potholing are included in this drawing set. Send the amended drawing set to Contributed Assets by emailing inspections@goldcoast.qld.gov.au <i>Note: Changes made may require submission of a Minor or Other Change application in accordance with the Planning Act 2016.</i>						
13	Pre-start inspection Arrange a pre-start inspection prior to the commencement of works to complete the requirements identified in City Plan Policy SC6.12 – Land development guidelines for the following:						

	<table><tr><th>Purpose</th><th>Council contact</th></tr><tr><td>Review and discuss this Operational works – infrastructure approval.</td><td>Contributed Assets 07 5582 9034</td></tr><tr><td>Prior to requesting a Pre-start meeting, provide “for construction issue design drawings”, including amendments, following potholing undertaken as part of the preliminary site works. All design changes must be included in the drawing set. <i>Note:</i> <i>Changes made to the drawings may necessitate the submission of a Minor or Other Change development application, in accordance with the Planning Act 2016.</i></td><td>inspections@goldcoast.qld.gov.au</td></tr></table>	Purpose	Council contact	Review and discuss this Operational works – infrastructure approval.	Contributed Assets 07 5582 9034	Prior to requesting a Pre-start meeting, provide “for construction issue design drawings”, including amendments, following potholing undertaken as part of the preliminary site works. All design changes must be included in the drawing set. <i>Note:</i> <i>Changes made to the drawings may necessitate the submission of a Minor or Other Change development application, in accordance with the Planning Act 2016.</i>	inspections@goldcoast.qld.gov.au						
Purpose	Council contact												
Review and discuss this Operational works – infrastructure approval.	Contributed Assets 07 5582 9034												
Prior to requesting a Pre-start meeting, provide “for construction issue design drawings”, including amendments, following potholing undertaken as part of the preliminary site works. All design changes must be included in the drawing set. <i>Note:</i> <i>Changes made to the drawings may necessitate the submission of a Minor or Other Change development application, in accordance with the Planning Act 2016.</i>	inspections@goldcoast.qld.gov.au												
Copies of applicable material including this decision notice and stamped approved plans, drawings and reports are to be available for the meeting and kept on site during construction.													
14	Hold point inspection Arrange a hold point inspection to complete the requirements identified in City Plan Policy SC.6.12 – Land development guidelines / SC6.13 - Landscape work of the City Plan for the following: <table><tr><th>Purpose</th><th>Hold Point</th><th>Council contact</th></tr><tr><td>Confirm works have been undertaken in accordance with the operational works approval and associated hold point requirements identified in SC6.12 City Plan Policy – Land development guidelines</td><td>As indicated in SC6.12 City Plan Policy – Land development guidelines</td><td>Contributed Assets (07) 5582 9034</td></tr><tr><td>Undertake a vehicle crossing pre-pour inspection to ensure work is in accordance with the Operational works approval inclusive of any necessary footpath tie ins</td><td>Prior to placement of concrete</td><td>Development Compliance (07) 5582 8184</td></tr><tr><td>Undertake a vehicle crossing post-pour inspection to ensure work is in accordance with the Operational works approval</td><td>After placement of concrete</td><td>Development Compliance (07) 5582 8184</td></tr></table>	Purpose	Hold Point	Council contact	Confirm works have been undertaken in accordance with the operational works approval and associated hold point requirements identified in SC6.12 City Plan Policy – Land development guidelines	As indicated in SC6.12 City Plan Policy – Land development guidelines	Contributed Assets (07) 5582 9034	Undertake a vehicle crossing pre-pour inspection to ensure work is in accordance with the Operational works approval inclusive of any necessary footpath tie ins	Prior to placement of concrete	Development Compliance (07) 5582 8184	Undertake a vehicle crossing post-pour inspection to ensure work is in accordance with the Operational works approval	After placement of concrete	Development Compliance (07) 5582 8184
Purpose	Hold Point	Council contact											
Confirm works have been undertaken in accordance with the operational works approval and associated hold point requirements identified in SC6.12 City Plan Policy – Land development guidelines	As indicated in SC6.12 City Plan Policy – Land development guidelines	Contributed Assets (07) 5582 9034											
Undertake a vehicle crossing pre-pour inspection to ensure work is in accordance with the Operational works approval inclusive of any necessary footpath tie ins	Prior to placement of concrete	Development Compliance (07) 5582 8184											
Undertake a vehicle crossing post-pour inspection to ensure work is in accordance with the Operational works approval	After placement of concrete	Development Compliance (07) 5582 8184											
Copies of applicable material including this decision notice and stamped approved plans, drawings and reports are to be available for the meeting and kept on site during construction.													
15	On maintenance Arrange an on maintenance meeting to complete the requirements identified in City Plan Policy SC.6.12 – Land development guidelines for the following: <table><tr><th>Purpose</th><th>Hold Point</th><th>Council contact</th></tr><tr><td>Confirm completion of works have been undertaken in accordance with this approval</td><td>Prior to commencement of the on maintenance period</td><td>Contributed Assets 07 5582 9034</td></tr></table>	Purpose	Hold Point	Council contact	Confirm completion of works have been undertaken in accordance with this approval	Prior to commencement of the on maintenance period	Contributed Assets 07 5582 9034						
Purpose	Hold Point	Council contact											
Confirm completion of works have been undertaken in accordance with this approval	Prior to commencement of the on maintenance period	Contributed Assets 07 5582 9034											
Copies of applicable material including this decision notice and stamped approved plans, drawings and reports are to be available for the meeting and kept on site during construction.													

16	Off maintenance Arrange an off maintenance meeting to complete the requirements identified in City Plan Policy SC6.12 – Land development guidelines for the following: <table><tr><th>Purpose</th><th>Hold Point</th><th>Council contact</th></tr><tr><td>Confirmation works have been undertaken in accordance with the Operational works, Works for infrastructure approval</td><td>Prior to Asset handover / conclusion of on maintenance period</td><td>Contributed Assets (07) 5582 9034</td></tr></table> Copies of applicable material including this decision notice and stamped approved plans, drawings and reports are to be available for the meeting and kept on site during construction.	Purpose	Hold Point	Council contact	Confirmation works have been undertaken in accordance with the Operational works, Works for infrastructure approval	Prior to Asset handover / conclusion of on maintenance period	Contributed Assets (07) 5582 9034
Purpose	Hold Point	Council contact					
Confirmation works have been undertaken in accordance with the Operational works, Works for infrastructure approval	Prior to Asset handover / conclusion of on maintenance period	Contributed Assets (07) 5582 9034					
Advice Notes							
A	Further development permits / compliance permits Further development permits and/or compliance permits from Council are required to facilitate the development of the approved works identified in this decision notice. These include: <table><tr><th>Contributed Assets</th></tr><tr><td>Connections / disconnections: Application to work on the City's Infrastructure</td></tr><tr><td>Temporary Road Closure and Works Zone Permit Application</td></tr></table> A copy of this decision notice and accompanying stamped drawings / plans must be submitted with any subsequent application identified above.	Contributed Assets	Connections / disconnections: Application to work on the City's Infrastructure	Temporary Road Closure and Works Zone Permit Application			
Contributed Assets							
Connections / disconnections: Application to work on the City's Infrastructure							
Temporary Road Closure and Works Zone Permit Application							
B	Works in properties other than the development land Where development works or works required to service the development require access, works or otherwise on land that is not part of the development approval, the applicant is solely responsible for obtaining consent and providing such with the "Application to work on City's infrastructure". Council will not become involved in any disputes arising from attempts to obtain neighbouring landowners' consent and assumes no responsibility for any impacts this has on the development. Council shall not be held responsible for any delays, complications or otherwise related to obtaining consent from neighbouring landowners as this is a civil matter to be resolved between the relevant parties.						
C	Council water, sewer and stormwater infrastructure to be protected during site works The developer is responsible at all times for ensuring that Council's water, sewer and stormwater infrastructure is protected during construction activities on site. This may require physical protection measures to be put in place during works such as deliveries, moving heavy equipment into and out of the site, or when doing works in close proximity to water, sewer and stormwater assets. Where Council water, sewer and stormwater infrastructure is damaged during construction, Council will undertake immediate repairs and any costs associated with these repairs will be charged to the landowner, principal contractor or other relevant party. If further, more permanent repairs are required, such as replacement of mains, the landowner, principal contractor or other relevant party will first be given an opportunity to complete these works (other approvals may be required), or Council will undertake these works and pass the costs on to the landowner, principal contractor or other relevant party.						
D	Connections and disconnections Any connection / disconnection to the existing water and sewerage networks will be at the applicant's cost. Prior to the connection / disconnection taking place, the applicant must obtain written approval from Contributed Assets.						

	Refer to Water and Sewerage Connections Policy, available on Council's website http://www.cityofgoldcoast.com.au
E	Consistency with other related approvals The assessment and approval of the operational work the subject of this permit, has been attended to having regard to the conditions of COM/2025/97, dated 28 July 2025. Should any change to any of these approvals be sought and achieved, consideration by the applicant should also be had to the consequences on the related approvals (and the potential need to make subsequent changes to these related approvals).
F	Compliance with conditions Once this development approval takes effect, the conditions attach to the land and are applicable in perpetuity. It is a development offence to contravene a development approval, including any of its conditions.
G	Pavement designs Any pavement designs shown on the approved plans are considered 'indicative only'. Pavement designs are to be submitted to and approved by Contributed Assets in accordance with the Land Development Guidelines.
H	Development infrastructure Development infrastructure required to be provided in implementing this development approval is non-trunk development infrastructure unless otherwise stated in a condition of the approval
I	Indigenous cultural heritage legislation and duty of care requirement The <i>Aboriginal Cultural Heritage Act 2003</i> ('ACHA') is administered by the Department of Seniors, Disability Services and Aboriginal and Torres Strait Islander Partnerships (DSDSATSIP). The ACHA establishes a duty of care to take all reasonable and practicable measures to ensure any activity does not harm Aboriginal cultural heritage. This duty of care: - a Is not negated by the issuing of this development approval; - b Applies on all land and water, including freehold land; - c Lies with the person or entity conducting an activity; and - d If breached, is subject to criminal offence penalties. Those proposing an activity involving surface disturbance beyond that which has already occurred at the proposed site must observe this duty of care. Details of how to fulfil this duty of care are outlined in the duty of care guidelines gazetted with the ACHA. The applicant should contact DSDSATSIP's Cultural Heritage Coordination Unit on 1300 378 401 for further information on the responsibilities of developers under the ACHA.
J	Encroachment of works If any operational works, the subject of this approval encroaches on adjoining land, a letter from the adjoining owner must be submitted to Council consenting to the carrying out of these works.
K	Connections to, alteration or realignment of Council infrastructure Where development works require the connection to, alteration, removal or realignment of Council infrastructure or impact on other public utility infrastructure (e.g. telecommunications, electricity and gas), the applicant must obtain the necessary approvals from the relevant public utility authority prior to works commencing. Connection to, alteration, removal or realignment of Council infrastructure includes (but is not limited to) fire hydrants, water service meters, sewer maintenance hole covers, stormwater drainage infrastructure, reinstatement of maintenance hole covers, stormwater drainage infrastructure, crossovers, footpaths, road pavement, kerb and channel, kerb ramps, medians, traffic islands, road furniture, signage and line-marking.
L	Applicant responsibilities The applicant is responsible for securing all necessary approvals and tenure, providing statutory

	notifications and complying with all relevant laws. Nothing in this decision notice alleviates the need for the applicant to comply with all relevant local, State and Commonwealth laws and to ensure appropriate tenure arrangements have been made where the use of/reliance upon land other than that owned by the applicant is involved. Without limiting this obligation, the applicant is responsible for: - a Obtaining all other/further necessary approvals, licences, permits, resource entitlements etc by whatever name called required by law before the development the subject of this approval can be lawfully commenced and to carry out the activity for its duration. - b Providing any notifications required by law (by way of example only, to notify the administering authority pursuant to the <i>Environment Protection Act 1994</i> of environmental harm being caused/threatened by the activity, and upon becoming aware the premises is being used for a 'notifiable activity'). - c Securing tenure/permission from the relevant owner to use private or public land not owned by the applicant (including for access required by conditions of approval). - d Ensuring existing survey marks, including cadastral marks at property corners, i.e pegs or cadastral reference marks in the road reserve (permanent surveys marks, buried iron pins, and various marks in concrete or bitumen structure) are not interfered with. A Consulting Cadastral Surveyor must be contacted if survey marks are disturbed or destroyed during any works in relation to this or related approvals, to investigate and determine if any further action is required. More information on interference with survey marks is available under Section 42 of the <i>Survey and Mapping Infrastructure Act 2003</i>. - e Ensuring the correct siting of structures on the land. An identification survey demonstrating correct siting and setbacks of structures may be requested of the applicant to ensure compliance with this decision notice and applicable codes. - f Providing Council with proof of payment of the Portable Long Service Leave building construction levy (or proof of appropriate exemption) where the total value of the building and construction works exceeds \$150,000 (excluding GST). Acceptable proof of payment is a Q.Leave –Notification and Payment Form approved by the Authority. Proof of payment must be provided before Council can issue a development permit for the Operational works. This is a requirement of section 77(1) of the Building and Construction Industry (Portable Long Service Leave) Act 1991. - g Making payment of any outstanding Council rates and charges applicable to the development site prior to the lodgement of subdivision plans. - h Obtaining any necessary local government/state approvals where works require the installation of temporary ground anchoring into adjacent Road Reserves. Where ground anchoring is proposed into an adjacent private property, approval from the relevant property owners(s) is required.
M	Water usage The use of potable water is not permitted in activities associated with road and pavement construction, the compaction of fill material or dust suppression. The use of recycled water is encouraged, especially where other alternative sources do not exist. Where recycled water is proposed to be used, contact the Water and Waste Recycled Water Management Team. More information is available for viewing on Council's website http://www.goldcoast.qld.gov.au/environment/recycled-water-for-industry-7900.html
N	Fire ant control Most of the Gold Coast is located within Biosecurity zone 2 and must remain vigilant for the presence of fire ants. Under the Biosecurity Act 2014 all Queenslanders have a general obligation to take all reasonable steps to prevent the spread of fire ants. This obligation applies to individuals and organisations whose activities involve the movement or storage of fire ant carriers. The Biosecurity Regulation 2016 specifies how fire ant carriers such as soil, mulch, turf, potted plants, machinery, equipment, quarry, and mining materials originating from fire ant biosecurity zones must be managed throughout all stages of development. Other fire ant-safe practices include:

	• reporting suspect fire ant activity within 24 hours, by calling 132 ANT (13 22 68) or using our <u>online form</u>; • cleaning machinery, vehicles, and equipment before arriving at or leaving sites; • complying with treatment requirements where a site falls within a suppression treatment area; • ensuring contractors and workers are aware of their General Biosecurity Obligation and apply <u>fire ant safe practices</u>; and reviewing fire ant biosecurity
O	As-Constructed Stormwater Deviations Where stormwater lines do not fall within acceptable tolerances, Council may accept minor deviations in stormwater levels without requiring a minor change, provided the following are achieved: • A non-conformance report is submitted with the as-constructed information, endorsed by a Registered Professional Engineer of Queensland (RPEQ); and • The constructed gradients are within the limits stipulated in section 7.12 of QUDM. This note is advisory only and does not alter or replace the conditions of this approval.
P	Design, Constructability and Minor change applications The application has been approved based on the information provided by the consultant. Council is not liable for any design or constructability issues experienced on-site. All necessary steps must be taken prior to construction to validate the information in the designs, including locating services. Should any changes be required to the design to ensure it can be constructed in compliance with relevant engineering standards; a Minor Change application (Section 78 of the <i>Planning Act 2016</i>) must be submitted and approved by Council prior to lodging a request for a Pre-Start meeting.